

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20233582
Address: 3640 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	Mitchell Schwarz	Partial	Tuesday, May 07, 2024

Informational:

1	THE FOLLOWING AREAS ARE APPROVED	exterior walls sheathing interior walls truss hold downs and lateral bracing is to plans
---	----------------------------------	--

Corrective Action Required:

2	Misc	-address over notched and cut studs in NW room -missing anchor bolts see NE corner of building and confirm through
---	------	---

Comments: