

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20233582  
Address: 3640 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	Mitchell Schwarz	Failed	Wednesday, May 08, 2024

Informational:

1	THE FOLLOWING AREAS ARE APPROVED	exterior walls sheathing interior walls truss hold downs and lateral bracing is to plans
---	----------------------------------	------------------------------------------------------------------------------------------------

Corrective Action Required:

2	Misc	-address over notched and cut studs in NW room (have engineer address)
---	------	------------------------------------------------------------------------

**Comments:**