

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240309
Address: 3736 SW CLAYTON PL, LEES SUMMIT, MO 640823738 SW CLAYTON PL, LEES SUMMIT, MO
640823740 SW CLAYTON PL, LEES SUMMIT, MO 640823734 SW CLAYTON PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Kyle Beard	Failed	Wednesday, May 08, 2024

Corrective Action Required:

2	Miscellaneous Correction	3734 SW Clayton. Rated assembly
		Roof vent hole cut out within 4 feet of rated wall
		3736
		Vertical fire block basement S/W corner at the top
		3740
		Roof vent cut in rated assembly decking

Comments: