

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240309
Address: 3736 SW CLAYTON PL, LEES SUMMIT, MO 640823738 SW CLAYTON PL, LEES SUMMIT, MO
640823740 SW CLAYTON PL, LEES SUMMIT, MO 640823734 SW CLAYTON PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Wednesday, May 08, 2024

Corrective Action Required:

2	Miscellaneous Correction	3734 SW Clayton. All rough
		Garage sole plate is missing the 5/8 inch anchor bolt with a plate
		3736
		Fire block top plate in basement closet
		3738
		Fire block top plate in closet of basement
		Add stud in basement closet

Comments: