

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20235258

Address: 817 NE ALGONQUIN ST, LEES SUMMIT, MO 64064  
819 NE ALGONQUIN ST, LEES SUMMIT, MO 64064  
815 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Khanh Nguyen	Failed	Wednesday, May 08, 2024

Corrective Action Required:

1	Misc	Provide verification of the 2-hr fire separation extended through the rear roof soffits **Fire-block gaps and opening
---	------	---

**Comments:**