

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20240118
Address: 515 NW MOORE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Sediment Control (ESC) Inspection	John Jackson	Partial	Wednesday, May 01, 2024

Corrective Action Required:

1	Misc	05/01/24 JMJ Erosion contractor has started to install erosion control fence on the Northside of project.
		05/08/24 Wednesday JMJ Contractor need to repair silt fence on the Northside of project damage appear occur due to construction work.

Comments: