

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20231450

Address: 410 NW CHIPMAN RD, LEES SUMMIT, MO 64086400 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer Construction Inspection</b>	John Jackson	Partial	Wednesday, May 08, 2024

Informational:

1 Misc

05/08/24 Wednesday JMJ

Contractor installed approximately 70' of 4" SDR-26 to the building and grease trap. Contractor tie-in to public sanitary 6" main. Construction of sanitary storm appear to correct as per project plans.

**Comments:**