# CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

# **DEVSERVICES.CITYOFLS.NET**

# **Inspection Summary**

Permit #: PRRES20215829

Address: 2051 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Mitchell Schwarz Not Ready Thursday, May 09, 2024

Residential

## Corrective Action Required:

1 Misc Pay all fees

- -Address pending driveway and sidewalk inspection
- -splash blocks and sump pump discharge to extend 36" from foundation
- -anti-siphon device at water spigot in garage with screw sheared off.
- -garage door to be self closing and latching
- -GFCI protection for hydro massage bath tub in master to comply with code  $\,$

section E4209

-pump access for hydro tub shall comply with

P2720

- -deck post to beam connections do not meet code requirements
- -label all non GFCI outlets in unfinished Spaces
- -all non GFCI outlets in unfinished spaces shall be single receptacle outlets

Basement inspected up to all rough (still missing some fire blocking)

-fireblock furr down ends through out basement and have inspected before

covering.

### **Comments:**