

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231596
Address: 1121 SW CORINTHIAN LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Thursday, May 09, 2024

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">- Post permanent address- Open electrical box at front porch- Final grading and sod- Provide guard and handrail for stairs at garage- Provide hardware on sliding door at kitchen- Secure CSST within 12" of appliance at second floor Mechanical room- Install secondary locks on second floor sliding door- Handrail of stairs to upstairs does not extend to bottom riser- Ladder of Egress window over 18" to grade- Protect electrical panel from DWV above- Label all non- GFCI outlets- Install smoke detector in basement at furnace- Provide anti siphon device at main water spigot- Seal all exterior penetrations |
|---|------|--|

Comments: