

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20233152

Address: 451 SE OLDHAM PKWY, Unit:B, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Thursday, May 09, 2024

Corrective Action Required:

1	Misc	-Complete all corrections for LSFD -Provide accessible restroom signage -Secure whip at mini split -Label electrical panel -Provide cover and working GFCI at south exterior *Ok to move into office space
---	------	---

Comments: