

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231105
Address: 800 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Plumbing Inspection - Commercial	Robb Popp	Partial	Thursday, May 09, 2024

Corrective Action Required:

1	Misc	***Inspection for plumbing pre rock walls in back to back bathroom groups: Building A: 105- ok 107- Provide structural strap at over bored top plate, bocca plate and seal penetrations 108- Provide structural strap and bocca plate at top plate 109- Repair sheer wall 112- OK 205-207 OK 211- ok 212- Seal top plate
---	------	---

Comments: