

20300 W 207TH St
Spring Hill, KS 66083

PREMIER

BUILDING SUPPLY OF KANSAS CITY

Phone: 913.686.1812
www.premierbuildingsupply.com

Customer:
Clover & Hive

Job Name:
Marmalade Transitional

Address:
3220 SW Arboridge Dr

Salesperson:
Kyle Clifford

Designer:
Dereck Cooper

Date:
5/3/2024

Job #:
P240270

Scale:
1/4" = 1'

ROOF TRUSS PLACEMENT
DIAGRAM

EVERSTEAD
SHOP DRAWING / SUBMITTAL

REVIEW
SUBMITTAL WAS REVIEWED FOR DESIGN
CONFORMITY AND GENERAL CONFORMANCE TO
CONTRACT DOCUMENTS ONLY. THE CONTRACTOR
IS RESPONSIBLE FOR CONFIRMING AND
CORRELATING DIMENSIONS AT JOBSITE FOR
TOLERANCE, CLEARANCE, QUANTITIES,
FABRICATION, COORDINATION OF HIS OR HER
WORK WITH OTHER TRADES, AND FULL
COMPLIANCE WITH CONTRACT DOCUMENTS.

STATUS:
APPROVED
05/08/2024

REVIEWED BY:
CPD
ENGINEER, EVERSTEAD ENGINEERING & DESIGN
LLC.

RELEASE FOR CONSTRUCTION
AS NOTED ON PLANS REVIEW
DEVELOPMENT SERVICES
LEE'S SUMMIT, MISSOURI
05/09/2024 2:34:49

HANGER SCHEDULE		QUANTI TY
●	LUS24	3
●	LUS26	0
●	HUS26	14
▲	HHUS26-2	0
▲	HGUS26-2	0
▲	HGUS28-2	0
■	THJA26	0
■	TJC37	0
■	THJU26	0
●	HUS28	0
●	HUS28-2	0
●	HHUS210-2	0
▲	HHUS28-2	0
▲	LUS28	0
▲	SUL24	0
■	SUL26	0
■	SUR24	0
■	SUR26	0
●	THA422	0
●	THA426	0
●	THAC422	0
▲	THAC426	0
▲	THASL29	0
▲	THASR29	0
■	TBE4	0
■	TBE6	0
	SDWC15600	70

◀ - EL EXTREMO IZQUIERDO DE LOS TRUSSES (VEA LOS PERFILES)

TODAS LAS DIMENSIONES PARA LAS TRUSSES SON DE FUERA DE LA MADERA (u.n.o.)

ESTABLECER LOS TRUSSES NIVELADAS CON LA ESTRUCTURA (u.n.o.)

◀ - LEFT END OF TRUSS (SEE TRUSS PROFILES)

ALL ROOF TRUSS DIMENSIONS ARE FROM OUTSIDE EDGE OF STUD (u.n.o.)

SET ROOF TRUSSES FLUSH WITH FRAMING (u.n.o.)

WARNING: Trusses must be handled with care to prevent damage and injury.

This truss placement diagram is to be used only as an installation aid; it is not a structural diagram. These trusses are designed as individual building components to be incorporated into the building design at the the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing.

Professional advice should be sought regarding handling, installation, temporary and permanent bracing before erecting trusses. Temporary and permanent bracing is required during installation of trusses to prevent possible collapse.

For general guidance regarding bracing, consult "BCSI-06" available jointly from WTCA & TPI.

Premier Building Supply must be notified of any issues requiring a back charge prior to any work being done. Premier Building Supply reserves the right to use it's service staff in lieu of being back charged.

ROOF PITCH FRONT TO BACK: 8/12, 4/12
SOFFIT DESIGNED FOR 12" O.H
HEEL HEIGHT: 10", 12"

ROOF PITCH LEFT TO RIGHT: 10/12
SOFFIT DESIGNED FOR 12" O.H
HEEL HEIGHT: 12"

ALL CEILINGS ARE FLAT UNLESS OTHERWISE NOTED

ROTATE ATTIC ACCESS TO ALIGN WITH TRUSS DIRECTION.

SEE PLACEMENT PLAN FOR ADDITIONAL