

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241971
Address: 3828 SW RAVENGATE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Kyle Beard	Passed	Friday, May 10, 2024

Informational:

1	Miscellaneous Correction	Footing was passed by a third party. Exterior piers were not mentioned in the footing report
---	-----------------------------	--

Comments: