

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20231814  
Address: 2201 NE TOWN CENTRE BLVD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection</b>	Khanh Nguyen	Failed	Friday, May 10, 2024

Corrective Action Required:

1	Misc	-Ground the fire pump service to water service per code
		-Fire pump: have engineer address conductor size to motor per NEC 430; equipment grounding conductor to pump shall be per NEC 250.122 (#3 copper)

**\*\*Main building 2000 amp electrical service approved for release**

**Comments:**