

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241323
Address: 1929 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Friday, May 10, 2024

Corrective Action Required:

1	Miscellaneous Correction	Garage portal framing is not to code. See code R602.10.6.2, R602.10.5 and table R602.6.4
---	--------------------------	--

This inspection was for garage portal framing only

Comments: