

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20230570
Address: 1950 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Khanh Nguyen	Partial	Friday, May 10, 2024

Informational:	In-wall OK:
1 Misc	-Exterior wall framing
	-Rm
	108,161,163,165,167,169,170,171,172,174,175,176,177,178,179,182,183,185,186,
	190,191,192,195,196,197,199
	-South wall of hall 150,
	100,100B,102,103,104,105,107,108,109,111,112,113,115,116,117,118,119,121,12
	2,123,124,125,126,127,128,129,131,132,133,134,135,136,137,138,139,142,144,14
	6,148,157,

Corrective Action Required:	
2 Misc	-Rm OR1: Route electrical to inside stud space; maximum size electrical box
	allowed in rated wall is no more than 16 sq inches

Comments: