

David P. Ainsworth, P.E.
1200 NW Hearnese Ave, Blue Springs, MO 64015
Cell Phone: 816-682-2093
Email: dainsworth@chelepis.com

May 9, 2024

Mr. Bill Wilson
M. L. Crose Foundations
4512 N Allison Rd
Sibley, MO 64088

Re: 2127 SW Hook Farm Dr
Lee's Summit, MO
Hook Farm Lot 105
SAB Permit 2024-2151
3rd Party Subgrade Inspection

Dear Mr. Wilson:

On May 9, 2024 I inspected the subgrade for the foundation at the above referenced property.

Subgrade was mostly clay and was solid.

Probes with a penetrometer showed soil bearing capacity in excess of 5,000 psf which is much greater than the minimum required of 2,000 psf.

In summary, the subgrade is approved for the proposed basement foundation.

Cordially,



David P. Ainsworth, P.E.

