

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216099
Address: 4728 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Alex Fischer	Failed	Monday, May 13, 2024

Corrective Action Required:

1	Misc	-Erosion control failed 24hrs to repair/replace -GFCI's missing in garage -Label all non GFCI's in garage -GFCI's not functioning on 1st floor -Electrical service panel cover missing/not labeled -Final grade and sod not in place -Gutters, downspouts and splash blocks missing -Pay fees
---	------	--

Comments: