

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240775
Address: 3521 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Alex Fischer	Failed	Monday, May 13, 2024

Partial Correction:

1	Miscellaneous Correction	3521 SE Corbin. All rough Exterior garage portal is not nailed to the top plate Stair stringers must be supported on platforms and 2x10's at least by 1 1/2 inches
---	--------------------------	--

Comments: