

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20231814  
Address: 2201 NE TOWN CENTRE BLVD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection</b>	Khanh Nguyen	Passed	Tuesday, May 14, 2024

Corrective Action Required:

1	Misc	**Main building 2000 amp electrical service
---	------	---

Engineer to address why the fire pump service does not have the grounded service conductor. How short-circuit or ground fault protection is provided without the service grounded conductor

**Comments:**