

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231814
Address: 2201 NE TOWN CENTRE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Khanh Nguyen	Failed	Tuesday, May 14, 2024

Corrective Action Required:

1	Misc	**Main building 2000 amp electrical service
---	------	---

Engineer to address why the fire pump service does not have the grounded service conductor. How short-circuit or ground fault protection is provided without the service grounded conductor

Comments: