

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20230682  
Address: 1501 SW ARBORWALK BLVD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Vacuum</b>	Patrick Schonfeldt	Passed	Tuesday, May 14, 2024

Informational:  
1            Misc            5-14-24 PS Inspected vac test at SS 1-4. Test had passed prior but ring sections were removed for service line install to manhole requiring a new test to be performed. Test passed

**Comments:**