

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215829
Address: 2051 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Devon Perry	Passed	Wednesday, May 15, 2024

Corrective Action Required:

1 Misc 3-13-24 Dustin A, DW is cracked on right panel and will need to be replaced. A new pre pour inspection will need to be performed before pouring new section

5-15-24 DP. Repairs have been made, does not seem that a pre inspection was called in as Dustin requested. Cross slopes are in compliance. Passed.

Comments: