

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20231975  
Address: 1550 SE HAMBLER RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                            | Inspector:   | Outcome: | Date:                   |
|--|--------------|----------|-------------------------|
| <b>Footing Inspection - Commercial</b> | Alex Fischer | Failed   | Wednesday, May 15, 2024 |

Corrective Action Required:

|   |      |   |
|---|------|---|
| 1 | Misc | -Provide city approved, stamped plans for inspection<br>-Provide 3" clearance to earth at all reinforcements<br>-Remove all water and loose soil/debris from footings |
|---|------|---|

**Comments:**