

DEVELOPMENT SERVICES

Residential Plan Review

May 15, 2024

CLAYTON PROPERTIES GROUP, INC 120 SE 30TH ST LEES SUMMIT, MO 64082 (816) 246-6700

Permit No: PRRES20242328

Plan Name:

Project Address: 3505 SE CORBIN DR, LEES SUMMIT, MO 64082

Parcel Number: 70500041200000000

Location: COBEY CREEK - 1ST PLAT---LOT 151

Type of Work: NEW SINGLE FAMILY

Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY

Description: NEW HOUSE. FINISHED/UNFINISHED BASEMENT. ROOF TRUSSES.

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and upload the revised documents and/or additional information to the application through the online portal. Please contact the Development Services Department with any questions you may have.

Development Services Department (816) 969-1200

Plot Plan Review Reviewed By: Andrea Sessler Rejected

1. The side yard dimensions must be provided on the plot plan.

NORTH SIDE YARD PROPERTY LINE IS NOT CALLED OUT.

2. Drainage swales/berms: provide cross-section elevations as required to conform to the accepted "As graded" Master Drainge Plan (MDP), include cross-section detail from MDP.

Residential Plan Review Reviewed By: Andrea Sessler Rejected

1. Identify emergency escape openings from bedrooms and basement(s). (IRC Section R310 as amended per Ordinance)

LABEL BEDROOM 2 AND BEDROOM 3 EGRESS

Planning Review RES Reviewed By: lan Trefren Approved

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

Residential Area:			
Residential, Finished basements		448	
Residential, garage		573	
Residential, Living Area (Not Finished Basement) Residential, Un-Finished basements		1416 59	
Roofing Material		Number of Bathrooms	3
Number of Bedrooms	2	Number of Stories	1
Number of Living Units	1	Total Living Area	1864