



May 15, 2024

ABI  
1271 NE Delta School Rd  
Lee's Summit, MO 64064

**RE: Column Pad Inspection for Lot # 134 Manor at Stoney Creek – 1929 SW Merryman Dr  
Lee's Summit, MO – Permit # 2024 1323**

On May 14, 2024, a special inspection was performed by Everstead at the above referenced property. The purpose of this inspection was to determine that the column pad in support of the W8x10 in the lower level was constructed per Everstead specifications.

- Everstead verified that the column pad size was a minimum 36"x36"x12".
- Steel pad was present with #4's at 6" OC EW.
- Column pad is approved for concrete.

We would like to thank you for the opportunity to consult you on your project. Please feel free to contact us if you have any questions regarding this report or need any further consultation.

Sincerely,

A handwritten signature in blue ink, appearing to read "B. Huxol", is written over a light blue horizontal line.

Bradley Huxol, PE

