

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20230570
Address: 1950 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------------|--------------|----------|-------------------------|
| Rated Assembly Inspection | Khanh Nguyen | Partial | Wednesday, May 15, 2024 |

| | |
|----------------|--|
| Informational: | |
| 1 Misc | Fire-rated wall below ceiling line screw pattern OK: -Smoke wall 161,163,165,167,169 Fire-rated wall above ceiling screw pattern line OK: -Smoke wall (both sides) from rm 161->179->end of hall 168; 171,173,182,180, 184, 192 |

| | |
|-----------------------------|-------------------------------------|
| Corrective Action Required: | |
| 2 Misc | Screw board to bottom track @ 8" oc |

Comments: