

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20235740  
Address: 2135 SW HOOK FARM DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Dustin Agcopra	Failed	Thursday, May 16, 2024

Informational:  
1 Misc 5-9-24 Dustin A, Dw is formed and compacted to city specs, Approved to pour  
5-16-24 Dustin A, Dw is poured, slopes are in compliance. The wing on left side of approach is cracked and will need to be replaced.

**Comments:**