

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234908
Address: 2143 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, May 13, 2024

Corrective Action Required:
2 Misc

-all 2x6 walls shall have double king studs at door and window openings per plans (address cut header and over notched king studs at front door now missing jack studs while trying to add king studs.)

Do not insulate

Comments: