

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20240366

Address: 1439 SW WINTHROP TER, LEES SUMMIT, MO 64081  
1437 SW WINTHROP TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection</b>	Alex Fischer	Failed	Thursday, May 16, 2024

Corrective Action Required:

1	Misc	-Secure all romex in basement chase both units -Green ground screw needs to be removed from both breaker panels -Provide UL listing documentation of grounding clamps
---	------	---

**Comments:**