



May 8, 2024

KC Concrete

Re: 2219 Hook Farm Dr
Lee's Summit, MO
Lot 114, Hook Farms
Permit: PRRES20240725

Apex Engineers, Inc. observed the preparation for the suspended garage slab at the above-referenced address. Our firm was on site from 1:00 pm to 1:30 pm.

The garage slab will be suspended. The forms and reinforcing steel were found to be clean, well aligned, properly supported, and in general compliance with the approved print.

Note:

- At the time of the inspection the temperature was 73°F.
- Erosion control was in place at the time of the inspection.

Our firm recommends approval of the suspended garage slab for the placement of concrete. This report does not constitute approval by the enforcing jurisdiction

LIMITATIONS

The recommendations and conclusions given in this report are based on the observed conditions at the time of this site visit. The scope of our services was only to observe the installation of the slab formwork and reinforcing steel.

The contractor is responsible for following ACI cold weather protection methods; therefore, Apex Engineers, Inc. cannot be held responsible for the impact and/or damages caused to the structure if ACI cold weather procedures are not followed and maintained.

Please call if Apex Engineers, Inc. can be of further assistance.

Best Regards,

Nick A. Shifflett, E.I.T.
Field Engineer

Clayton J. Hess,
Principal

