

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20240499
Address: 2237 NE TOWN CENTRE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Failed	Thursday, May 16, 2024

Corrective Action Required:

1	Misc	*Office area only: -Secure all mc within 12" of boxes -Install all missing cover plates -Secure all lights at opposite corners -Secure/support mc at max 6' horizontal -Support flex duct per code
---	------	---

Comments: