

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20235258

Address: 817 NE ALGONQUIN ST, LEES SUMMIT, MO 64064
819 NE ALGONQUIN ST, LEES SUMMIT, MO 64064
64064815 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Failed	Friday, May 17, 2024

Corrective Action Required:

1	Misc	Provide verification of the 2-hr fire separation extended through the rear roof soffits **Fire-block gaps and opening
---	------	---

Comments: