CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241005

Address: 1628 SW ARBORWAY TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Mitchell Schwarz Failed Friday, May 17, 2024

Residential

Corrective Action Required:

1 Misc

- -sister over notched studs to full length in garage
- -fire block chase in garage to ceiling space
- -fire block wall space to ceiling furr down in garage/laundry
- -seal penetration for gas in kitchen
- -block wall space to ceiling space under stairs
- -address broken truss 2nd floor
- -fire block top of furr out wall in stairwell
- -nail exterior wall corners to plans
- -complete ducting hvac in basement
- -provide future vent for basement bath
- -complete cspf nailing at rim

-

Comments: