

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240893
Address: 4805 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	Khanh Nguyen	Failed	Monday, May 20, 2024

Corrective Action Required:

1	Misc	-Provide AFCI breakers for outlets per NEC 210.12 -The refrigerator receptacle outlet listed within 6 ft of the wet bar sink shall be gfci-protected. Outlet has hot and neutral connectors reversed
---	------	---

Comments: