

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241323  
Address: 1929 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Kyle Beard	Failed	Monday, May 20, 2024

Corrective Action Required:

2	Miscellaneous Correction	- Garage CS-PF needs to be nailed across the top into the top plate - Front porch truss tie down screws can not be verified due to being covered - Some of the front porch truss hangers are covered and can not be verified
---	--------------------------	--

This was a partial all rough inspection for the front porch and garage portal only

**Comments:**