## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20240334

Address: 3529 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Shawn Hoffman Failed Monday, May 20, 2024

Residential

Corrective Action Required:

1 Misc - Final grading and sod

- Provide splash pads 36" away from foundation

- Sump discharge to be 36" away from foundation

- Seal all exterior penetrations

- Fire block around gas line in garage

- Fire block above electrical panel in garage

- Fire block above garage doors, at gaps in sheet rock

- A/v outlet in furnace room be single not duplex and labeled non-gfci or

change to gfci

- Anti siphon on water main spigot in furnace room has no set screw

- Top riser of lower stairs over 7 3/4" and out of 3/8" variance

- Provide landing for deck stairs

**Comments:**