

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20240499  
Address: 2237 NE TOWN CENTRE BLVD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Khanh Nguyen	Failed	Monday, May 20, 2024

Corrective Action Required:

1 Misc

\*Office area only:

-Support lights \*\*Need bigger and continuous (no splices) wood joists to carry light weight. Use 2x10

-Support flex duct per code \*\*Support with strap min 1.5" wide

**Comments:**