

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20240759  
Address: 3517 SE CORBIN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Shawn Hoffman	Failed	Monday, May 20, 2024

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>- Final grading and sod</li><li>- Address to contrasting in color and illuminated</li><li>- Sump discharge to be 36" away from foundation</li><li>- Provide splash pads</li><li>- No anti tipping device on range</li></ul>
---	------	---

**Comments:**