

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20234906  
Address: 2307 SW SERENA PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Tuesday, May 21, 2024

Corrective Action Required:

1 Misc

- address over drilled floor joist above garage for electrical (upload engineer letter for fix)
- fire block plumbing chase S garage wall to ceiling space (if using insulation must be packed tightly, securely and be Unfaced)
- fire block plumbing chase in pantry
- fire block plumbing chase to ceiling space and master bath wall space to furr down

**Comments:**