

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20230487  
Address: 2701 NE HAGAN RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Coliform Test 1</b>	Nick Scott	Passed	Wednesday, May 22, 2024

Informational:  
1 Misc 4-23-24 NS Site visited for first Bac-T test and was complete at 11am  
4-24-24 NS Site visited for second Bac-T test and was complete at 11am  
4-26-24 NS all Bac-T test passed

**Comments:**