

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234940
Address: 4720 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Thursday, May 23, 2024

Corrective Action Required:

1	Misc	**CLEAN OUT DIRT&SILT FENCE AROUND THE STORM INLET AT REAR CORNER OF LOT -Final grade, sod, downspout and sump pump extension -Make sure the water meter is flushed with final grade -Provide sewer tracer wire port at grade **Cannot check the below items due to area being closed off** -Support water service PEX line above grinder pump every 32" -Locate and provide access to ufer grounding connection
---	------	--

Comments: