

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233424
Address: 2747 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|-----------|------------------------|
| Occupancy Inspection - Codes Residential | Robb Popp | Not Ready | Thursday, May 23, 2024 |

Corrective Action Required:

1 Misc **House not ready for occupancy. No inspection performed. List is incomplete. Correct all of the following before re inspection:

- Open electrical boxes at front
- Illuminated address at front required
- Remove all material to access garage receptacles and panel
- Garage door must self close and latch

Comments: