

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20235554

Address: 816 NE ALGONQUIN ST, LEES SUMMIT, MO 64064
818 NE ALGONQUIN ST, LEES SUMMIT, MO 64064
64064814 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Thursday, May 23, 2024

Corrective Action Required:

1	Misc	Unit 814 and 818 only-OK to rock
---	------	----------------------------------

Unit 816:

- Fb fireplace space from roof space; fb foyer/master closet wall from room
- Cannot have roof ventilation opening located within 4 ft of firewall. Provide FlameBlock roof deck sheathing within 4 ft of firewall. Check all other units
- Close off gap at top of firewall at front bedroom

****OK TO INSULATE**

Comments: