

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20226005  
Address: 1901 SW RIVER RUN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Engineering</b>	Patrick Schonfeldt	Temporary C of O	Thursday, May 23, 2024

Informational:

1 Misc

- Remove plastic protective covers on truncated domes on sidewalk
- Remove all silt fence as vegetation has been established
- Provide splash blocks at downspouts, min 36" discharge from foundation
- Connect sewer tracer wire to tracer box and set tracer box to grade

Engineering TCO approval, 30 days

**Comments:**