



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20113619, Building Permit - Commercial  
Address: 880 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	John Borns	Partial	Friday, September 09, 2011

Partial Correction  
1 MISC

OK TO COVER WHEN READY WALL FRAMING AND IN-WALL  
SYSTEMS AT TYPE "B" WALL AT: 19' WALL @ SE CORNER; WALL  
@ NE CORNER

**Comments:**