

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20224994

Address: 520 NE TOWN CENTRE DR, Unit:R, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Thursday, May 23, 2024

Corrective Action Required:

1	Misc	-Footing not approved. Inspection was not scheduled for completion of the footing -Ground the panel disconnect to ufer (ufer rebar extension is not available) -Clearly label panel 20 to indicate that it supplies power to buildings R panel 18 as well
---	------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: