

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240644
Address: 1617 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Thursday, May 23, 2024

Informational:

1 Misc

Garage portal nailing inspected only.

Corrective Action Required:

2 Misc

Covered porch and patio inspected only.

Covered porch, already covered without inspection

Covered patio has sheathing on Joists covering hold down connections

Corrective Action Required:

3 Misc

No inspection performed NOT READY

-Complete fur downs throughout

-Address previous inspection items

-Truss hold downs not installed

Comments: