

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20233424  
Address: 2747 SW HEARTLAND RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Friday, May 24, 2024

Corrective Action Required:

1	Misc	-provide as graded plot plan -Garage door must self close and latch -identify sewer tracer wire -spark rings at basement wet bar outlets -install flood light at rear -will check outside items at re inspection, water meter, penetrations, tamper caps for A/c, exc(sprinklers going off during inspection)
---	------	--

**Comments:**