

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20235234
Address: 1512 SW HEARTWOOD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Alex Fischer	Failed	Monday, May 13, 2024

Corrective Action Required:

1	Misc	-Incorrect grounding clamps used replace with ones approved for aluminum wire -Gas line grounding conductor should be equivalent to #4 copper 6 AWG is not please correct this
---	------	---

Comments: